

2015 CONSUMERS ANNUAL REPORT ON WATER QUALITY

ATTENTION: THIS IS AN IMPORTANT REPORT ON WATER QUALITY AND SAFETY

The City of Birmingham, The Southeastern Oakland County Water Authority and the Detroit Water and Sewerage Department (DWSD) are proud of the fine drinking water they supply and are honored to provide this report to you. The 2015 Consumers Annual Report on Water Quality shows the sources of our water, lists the results of our tests, and contains important information about water and health. We will notify you immediately if there is ever any reason for concern about our water. We are pleased to show you how we have surpassed water quality standards as mandated by the Environmental Protection Agency (EPA) and the Michigan Department of Environmental Quality (MDEQ).

About the System

The City of Birmingham purchases water from the Southeastern Oakland County Water Authority (SOCWA) at four locations. SOCWA provides Detroit water through its member distribution systems to a population of 210,000 within a 56 square mile area. Current members are: Berkley, Beverly Hills, Bingham Farms, Birmingham, Clawson, Huntington Woods, Lathrup Village, Pleasant Ridge, Royal Oak, Southfield and Southfield Township and to our customers Bloomfield Hills and Bloomfield Township.

Your source water may at times come from the Detroit River, situated within the Lake St. Clair, Clinton River, Detroit River, Rouge River, Ecorse River, in the U.S. and parts of the Thames River, Little River, Turkey Creek and Sydenham watersheds in Canada. The Michigan Department of Environmental Quality in partnership with the U.S. Geological Survey, the Detroit Water and Sewerage Department, and the Michigan Public Health Institute performed a source water assessment in 2004 to determine the susceptibility of potential contamination. The susceptibility rating is on a seven-tiered scale from "very low" to "very high" based primarily on geologic sensitivity, water chemistry, and contaminant sources. The susceptibility of our Detroit River source water intakes were determined to be highly susceptible to potential contamination. However, all four Detroit water treatment plants that use source water from Detroit River have historically provided satisfactory treatment of this source water to meet drinking water standards.

Your source water may at times come from the lower Lake Huron watershed. The watershed includes numerous short, seasonal streams that drain to Lake Huron. The Michigan Department of Environmental Quality in partnership with the U.S. Geological Survey, the Detroit Water and Sewerage Department, and the Michigan Public Health Institute performed a source water assessment in 2004 to determine the susceptibility of potential contamination. The susceptibility rating is a seven-tiered scale ranging from "very low" to "very high" based primarily on geologic sensitivity, water chemistry, and contaminant sources. The Lake Huron Source water intake is categorized as having a moderately low susceptibility to potential contaminant sources. The Lake Huron water treatment plant has historically provided satisfactory treatment of this source water to meet drinking water standards. In 2015, DWSD received a grant from The Michigan Department of Environmental Quality to develop a source water protection program for the Lake Huron water treatment plant intake. The program includes seven elements that include the following: roles and duties of government units and water supply agencies, delineation of a source water protection area, identification of potential of source water protection area, management approaches

for protection, contingency plans, siting of new sources and public participation. If you would like to know more information about the Source Water Assessment Report, please contact DWSD Water Quality Division at 313-926-8102.

Additional Information


In order to ensure that tap water is safe to drink, EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organics, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **Environmental Protection Agency's Safe Drinking Water Hotline at 800-426-4791.**



2015 Key to the Detected Contaminants Table

Symbol	Abbreviation	Definition/Explanation
>	Greater than	
AL	Action Level	The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements which a water system must follow.
HAA5	Halooacetic Acids	HAA5 is the total of bromoacetic, chloroacetic, dibromoacetic, dichloroacetic, and trichloroacetic acids. Compliance is based on the total.
LRAA	Locational Running Annual Average	
MCL	Maximum Contaminant Level	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal	The level of contaminant in drinking water below which there is no known or expected risk to health.
MRDL	Maximum Residual Disinfectant Level	The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MRDLG	Maximum Residual Disinfectant Level Goal	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.
n/a	not applicable	
ND	Not Detected	
NTU	Nephelometric Turbidity Units	Measures the cloudiness of water.
pCi/L	Picocuries Per Liter	A measure of radioactivity
ppb	Parts Per Billion (one in one billion)	The ppb is equivalent to micrograms per liter. A microgram = 1/1000 milligram.
ppm	Parts Per Million (one in one million)	The ppm is equivalent to milligrams per liter. A milligram = 1/1000 gram.
RAA	Running Annual Average	
TT	Treatment Technique	A required process intended to reduce the level of a contaminant in drinking water.
TTHM	Total Trihalomethanes	Total Trihalomethanes is the sum of chloroform, bromodichloromethane, dibromochloromethane and bromoform. Compliance is based on the total.
µmhos	Micromhos	Measure of electrical conductance of water
°C	Celsius	A scale of temperature in which water freezes at 0° and boils at 100° under standard conditions.

Springwells Water Treatment Plant 2015 Regulated Detected Contaminants Tables

Regulated Contaminant	Test Date	Unit	Health Goal MCLG	Allowed Level MCL	Highest Level Detected	Range of Detection	Violation yes/no	Major Sources in Drinking Water
Inorganic Chemicals – Monitoring at the Plant Finished Water Tap								
Fluoride	5/11/15	ppm	4	4	0.45	n/a	no	Erosion of natural deposits; Water additive, which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate	5/11/15	ppm	10	10	0.33	n/a	no	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Disinfectant Residuals – Monitoring in DWSD Distribution System By Treatment Plant								
Regulated Contaminant	Test Date	Unit	Health Goal MRDLG	Allowed Level MRDL	Highest RAA	Range of Detection	Violation yes/no	Major Sources in Drinking Water
Total Chlorine Residual	Jan-Dec 2015	ppm	4	4	0.74	0.66-0.79	no	Water additive used to control microbes
2015 Turbidity – Monitored every 4 hours at Plant Finished Water Tap								
Highest Single Measurement Cannot exceed 1 NTU			Lowest Monthly % of Samples Meeting Turbidity Limit of 0.3 NTU (minimum 95%)				Violation yes/no	Major Sources in Drinking Water
0.18 NTU			100%				no	Soil Runoff
Turbidity is a measure of the cloudiness of water. We monitor it because it is a good indicator of the effectiveness of our filtration system.								
Regulated Contaminant	Treatment Technique							Typical Source of Contaminant
Total Organic Carbon (ppm)	The Total Organic Carbon (TOC) removal ratio is calculated as the ratio between the actual TOC removal and the TOC removal requirements. The TOC was measured each quarter and because the level was low, there is no requirement for TOC removal requirement.							Erosion of natural deposits

2015 Special Monitoring

Contaminant	MCLG	MCL	Level Detected	Source of Contamination
Sodium (ppm)	n/a	n/a	4.74	Erosion of natural deposits

Collection and sampling result information in the table provided by Detroit Water and Sewerage Department (DWSD) Water Quality, ML Semegen

**Lake Huron Water Treatment Plant
2015 Regulated Detected Contaminants Tables**

Regulated Contaminant	Test Date	Unit	Health Goal MCLG	Allowed Level MCL	Highest Level Detected	Range of Detection	Violation yes/no	Major Sources in Drinking Water
Inorganic Chemicals – Monitoring at the Plant Finished Water Tap								
Fluoride	5/11/15	ppm	4	4	0.43	n/a	no	Erosion of natural deposits; Water additive, which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate	5/11/15	ppm	10	10	0.30	n/a	no	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Disinfectant Residuals Monitoring in GLWA Distribution System by Treatment Plant								
Regulated Contaminant	Test Date	Unit	Health Goal MRDLG	Allowed Level MRDL	Highest RAA	Quarterly Range of Detection	Violation yes/no	Major Sources in Drinking Water
Total Chlorine Residual	Jan-Dec 2015	ppm	4	4	0.82	0.71-0.91	no	Water additive used to control microbes
Regulated Contaminant	Treatment Technique							Typical Source of Contaminant
Total Organic Carbon (ppm)	The Total Organic Carbon (TOC) removal ratio is calculated as the ratio between the actual TOC removal and the TOC removal requirements. The TOC was measured each month and because the level was low, there is no requirement for TOC removal.							Erosion of natural deposits
2015 Turbidity – Monitored every 4 hours at Plant Finished Water Tap								
Highest Single Measurement Cannot exceed 1 NTU		Lowest Monthly % of Samples Meeting Turbidity Limit of 0.3 NTU (minimum 95%)				Violation yes/no	Major Sources in Drinking Water	
0.2 NTU		100%				no	Soil Runoff	
Turbidity is a measure of the cloudiness of water. We monitor it because it is a good indicator of the effectiveness of our filtration system.								
Regulated Contaminant		Treatment Technique						Typical Source of Contaminant
Total Organic Carbon (ppm)		The Total Organic Carbon (TOC) removal ratio is calculated as the ratio between the actual TOC removal and the TOC removal requirements. The TOC was measured each quarter and because the level was low, there is no requirement for TOC removal.						Erosion of natural deposits
Regulated Contaminant		Test Date	Unit	Health Goal MCLG	Allowed Level MCL	Level Detected	Violation Yes/no	Major Sources in Drinking Water
Combined Radium Radium 226 and 228		5/13/14	pCi/L	0	5	0.86 + or – 0.55	no	Erosion of natural deposits
2015 Special Monitoring								
Contaminant		MCLG	MCL	Level Detected				Source of Contamination
Sodium (ppm)		n/a	n/a	4.00				Erosion of natural deposits
Collection, sampling result information and table provided by GLWA Water Quality Division, ML Semeegen								

Collection, sampling result information and table provided by GLWA Water Quality Division, ML Semegen

**Northeast Water Treatment Plant
2015 Regulated Detected Contaminants Tables**

Regulated Contaminant	Test Date	Unit	Health Goal MCLG	Allowed Level MCL	Highest Level Detected	Range of Detection	Violation yes/no	Major Sources in Drinking Water
Inorganic Chemicals – Monitoring at the Plant Finished Water Tap								
Fluoride	5/11/15	ppm	4	4	0.46	n/a	no	Erosion of natural deposits; Water additive, which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate	5/11/15	ppm	10	10	0.28	n/a	no	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Disinfectant Residual – Monitoring in Distribution System by Treatment Plant								
Regulated Contaminant	Test Date	Unit	Health Goal MRDLG	Allowed Level MRDL	Highest RAA	Range of Detection	Violation Yes/no	Major Sources in Drinking Water
Total Chlorine residual	Jan-Dec 2015	ppm	4	4	0.75	0.65-0.82	no	Water additive used to control microbes
2015 Turbidity – Monitored every 4 hours at Plant Finished Water Tap								
Highest Single Measurement Cannot exceed 1 NTU			Lowest Monthly % of Samples Meeting Turbidity Limit of 0.3 NTU (minimum 95%)				Violation yes/no	Major Sources in Drinking Water
0.17 NTU			100%				no	Soil Runoff
Turbidity is a measure of the cloudiness of water. We monitor it because it is a good indicator of the effectiveness of our filtration system.								
Regulated Contaminant	Treatment Technique							Typical Source of Contaminant
Total Organic Carbon (ppm)	The Total Organic Carbon (TOC) removal ratio is calculated as the ratio between the actual TOC removal and the TOC removal requirements. The TOC was measured each month and because the level was low, there is no requirement for TOC removal.							Erosion of natural deposits
2015 Special Monitoring								
Contaminant			MCLG	MCL	Level Detected			Source of Contamination
Sodium (ppm)			n/a	n/a	4.96			Erosion of natural deposits

Collection and sampling result information in the table provided by GLWA Water Quality Division, ML Semegen

City of Birmingham Water Quality Results

Disinfection By-Products – Monitoring in Distribution System Stage 2 Disinfection By-Products								
Regulated Contaminant	Test Date	Unit	Health Goal MCLG	Allowed Level MCL	Highest LRAA	Range of Detection	Violation yes/no	Major Sources in Drinking Water
Total Trihalomethanes (TTHM)	2015	ppb	n/a	80	20	13.4-22	no	By-product of drinking water chlorination
Haloacetic Acids (HAA5)	2015	ppb	n/a	60	9	6-10	no	By-product of drinking water disinfection

2014 Microbiological Contaminants – Monthly Monitoring in Distribution System					
Regulated Contaminant	MCLG	MCL	Highest Number Detected	Violation yes/no	Major Sources in Drinking Water
Total Coliform Bacteria	0	Presence of Coliform bacteria > 5% of monthly samples	0	no	Naturally present in the environment.
<i>E.coli</i> Bacteria	0	A routine sample and a repeat sample are total coliform positive, and one is also fecal or <i>E. coli</i> positive.	0	no	Human waste and animal fecal waste.

2014 Lead and Copper Monitoring at Customers' Tap								
Regulated Contaminant	Test Date	Unit	Health Goal MCLG	Action Level AL	90 th Percentile Value*	Number of Samples Over AL	Violation yes/no	Major Sources in Drinking Water
Lead	2014	ppb	0	15	0	0	no	Corrosion of household plumbing system; Erosion of natural deposits.
Copper	2014	ppb	1300	1300	82.5	0	no	Corrosion of household plumbing system; Erosion of natural deposits; Leaching from wood preservatives.

*The 90th percentile value means 90 percent of the homes tested have lead and copper levels below the given 90th percentile value. If the 90th percentile value is above the AL additional requirements must be met.

Important Health Information

Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Birmingham is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

People With Special Health Concerns

Some people may be more vulnerable to contaminants in drinking water than is the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791.

Questions:

Local Distribution: City of Birmingham, Public Works Administration (248) 530-1700.

Southeastern Oakland County Water Supply System – Water Authority

offices: (248) 288-5150. Visit our web site at www.socwa.org

Detroit Water and Sewerage Department – Water Quality Division: (313) 926-8128 – www.dwsd.org

Great Lakes Water Authority: www.glwater.org

Michigan Department of Environmental Quality: (586) 753-3755 – www.michigan.gov/deq

U.S. Environmental Protection Agency – Safe Drinking Water Hotline: (800) 426-4791.

Water quality data for community water systems throughout the United States is available at www.epa.gov/drink/